

D.Dis.A1/1240/2025  
Date:21.04.2025



Taluk Office,  
Cuddalore

**FORM - D**

Form of License under sub section (1) of section 6 of the Madras Public Building (Licensing) act 1965 (Madras Act 13 of 1965) referred to rule 6 of the Madras Public Building (Licensing Rules 1966)

**LICENSE**

**License No. 12/2025-2028**

**Challan No.20250325015919**  
**Dated: 25.03.2025 Rs.5000/-**

License is hereby renewed **ARISTO PUBLIC SCHOOL, THIRUPAPULIYUR, CUDDALORE TALUK** for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder.

The period of Validity of the License shall be from 11.02.2025 to 10.02.2028 (Both days inclusive)

*[Signature]*  
TAHSILDAR,  
CUDDALORE

**STATEMENT OF ACCOMPANY THE LICENSE**

<b>Location of the Building (Door, Street Number and Name of the Place)</b>	<b>Purpose for which the building is licensed to be used as a public building</b>	<b>No. of Persons to be accommodated</b>
T.S.NO.43/2 WARD.05, BLOCK NO.02 THIRUPPAPULIYUR CUDDALORE TALUK AND DISTRICT.	To run <b>ARISTO PUBLIC SCHOOL</b>	4000 Students (Four thousand only)

For ARISTO PUBLIC SCHOOL

*A. C. SAIL*  
Chairman.



*[Signature]*  
**MATHURA PRASAD PANDEY**  
PRINCIPAL  
**ARISTO PUBLIC SCHOOL**  
APS Avenue, Gadilam Bypass Road,  
Thirupapuliyyur, Cuddalore-607002.  
Tamil Nadu, India.

*[Signature]*  
21/4/25

# Er. K.G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG. NO. M-111304/0], PPE (PANEL REG. NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved Valuer / Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

DTCP Registered Structural Engineer (No. RSE / VR / May2019/007)

## CERTIFICATE OF STRUCTURAL SOUNDNESS STATEMENT ACCOMPANYING FORM-A

Ref No: CSS.NO.43/2 11.02.2025

Date: 11.02.2025

1. Door No of the Building : **ARISTO PUBLIC SCHOOL**  
T.S.NO: 43/2, Thirupathiripuliyur
2. Location (Street Name, Ward No., Name of the Place, i.e. Corporation/Municipality/Panchayat /Panchayat Union/Township/Cantonment, etc) : APS Avenue, Ward 5, Block-2  
Thirupathiripuliyur  
Cuddalore City Municipal Corporation
3. Year of construction : (1) Block – A – 2012 (5) Block – E-2007  
(2) Block – B -2017 (6) Block- F- 2016  
(3) Block - C- 2019  
(4) Block – D-2019
4. Approximate cost of construction as per current rates : 12, 00, 00, 000.00  
(Rupees Twelve crore only)
5. Purpose for which the building is being used or proposed to be used : Educational Purpose
6. Purpose for which the building hither been used : Meant for Education use
7. Details of construction of the building :
- a) Foundation : Isolated column Footing
- b) Basement : Frames & Brick Masonry
- c) Superstructure : Frames & Brick Masonry
- d) Floor & Roof : Tiled & marble floor RCC Roof/partly  
Metal sheet roof
- e) Area of the Building :

	Block-A RCC roof	Block -B RCC roof	Block -C RCC roof	Block -D RCC roof	Block -E Weather Coated with False ceiling	Block -F Weather Coated with False ceiling
G.F	14005.41	10356.92	3866.18	3615.38	9127.46	1572.75
F.F	13425.22	10356.92	3866.18	3615.38		
S.F	-	10356.92				
T.F	-	10356.92				
H.R./SECURITY ROOM	1246.54	639.64	63.25	53.50	73.06 (RCC)	

# Er. K.G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG. NO. M-111304/0], PPE (PANEL REG. NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved Valuer / Civil Engineer,


Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

DTCP Registered Structural Engineer (No. RSE / VR / May2019/007)

- f) Plot/Land Area : 10806 m<sup>2</sup> (or) 116348.39 Sq. ft
8. Period for which license is required : 11.02.2025 to 10.02.2028 (3 Years)
9. Number of persons to be accommodated : 4000 students
10. Applicant : **ARISTO PUBLIC SCHOOL,  
Thiruppapuliur, Cuddalore-2**

"Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to opinion a fresh license in case any addition or alternation is made to the existing building. I also undertake to obtain a fresh license if the purpose for which the license was granted fit the use of the building or a portion originally changed or altered subsequently."

Date: 11.02.2025

  
CHAIRMAN  
ARISTO PUBLIC SCHOOL  
APS AVENUE,  
GADILAM BY PASS ROAD,  
CUDDALORE - 607 002

Signature of the Owner of the Building

Date: 11.02.2025

Signature of the Registered Engineer,

  
Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C Eng.  
CLASS - IA REGISTERED ENGINEER,  
(Under Tamil Nadu Public Building Lic. Act)  
COLLECTORATE PANEL ENGINEER,  
Chartered Engineer, Approved Valuer  
D.No: 3/201, First Cross Street, Friends Nagar,  
SEMMANDALAM, CUDDALORE - 607 001.

# Er. K.G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG. NO. M-111304/0], PPE (PANEL REG. NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved Valuer / Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

DTCP Registered Structural Engineer (No. RSE / YR / May2019/007)

## FORM-B

(Form of certificate of structural soundness under sub section (4) of the Tamil Nadu Public Building Licensing) Act 1965 (Tamil nadu 13 of 1965) referred to in rule 4 of the Tamil nadu Public Buildings (Licensing) Rule 1966)

I certify that I have inspected the building, mentioned in the statement and furnish below its salient technical features.

### I.FOUNDATION:

- |  |   |                     |
|--|---|---------------------|
| 1. Depth below ground level  | : | 8'                  |
| 2. Nature of soil not with at foundation level                       | : | Sandy clay          |
| 3. Pressure at foundation  | : | 9 T/m <sup>2</sup>  |
| 4. Probable safe bearing capacity of the soil met with at foundation | : | 15 T/m <sup>2</sup> |

### II.SUPER STRUCTURE:

- |  |   |                              |
|--|---|------------------------------|
| 1. Maximum stress in the most critical Section of Masonry & concrete | : | Within safe allowable limits |
| 2. Nature of Masonry and concrete & its Safe Permissible stress      | : | Within safe allowable limits |

The structural soundness of the building has been verified by me with reference to I.S.I loading standards 878 (Latest Version) and other relevant Indian standards code of practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A license may be granted for the period from 11.02.2025 to 10.02.2028 (3 Years).

Date: 11.02.2025

Signature of the Engineer

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.  
CLASS - 1A REGISTERED ENGINEER  
(Under Tamil Nadu Public Building Licensing) Act 1966  
COLLECTORATE PANEL ENGINEER,  
Chartered Engineer, Approved Valuer  
D.N. 11/201, First Cross Street, Friends Nagar,  
Cuddalore - 607 001

# Er. K.G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG. NO. M-111304/0], PPE (PANEL REG. NO M2/80777/96), I V-REG. NO F-10285

Chartered Engineer (India), Approved Valuer / Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

DTCP Registered Structural Engineer (No. RSE / VR / May2019/007)

## FORM-C

### STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

1. Location of the Building  
(Door No, Street Name &  
Name of the Place) : **ARISTO PUBLIC SCHOOL**  
T.S.No:43/2, APS Avenue, Ward 5, Block-2  
Thiruppapuliur,  
Cuddalore Municipality.
2. Age of the Building : Block - A -13 Years Block - E-18 Years  
Block- B -8 Years Block - F-9 Years  
Block - C-6 Years  
Block - D-6 Years
3. Number of Storey : Block-A-(G+1) Block -E-(G.F only)  
Block - B (G+3) Block -F-(G .F only)  
Block -C-(G +1)  
Block -D-(G +1)
4. Short description of structures, Steel RCC  
framed or load bearing masonry : Framed Structure with RCC Roof  
& partly steel frames & truss
5. Purpose for which the building is certified for use : Meant for Educational use
6. The period for which the building will be  
Structurally sound : 11.02.2025 to 10.02.2028 (3 Years)
7. Number of persons to be Accommodated : 4000 Students
8. Remarks: : Certified that the buildings are Stable  
and fit for occupation.

Date: 11.02.2025

Signature of the Registered Engineer

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.

CLASS - IA REGISTERED ENGINEER

(Under Tamil Nadu Public Building Lic.A)

COLLECTORATE PANEL ENGINEER.

Chartered Engineer, Approved Valuer

3/201, 1st Cross Street, Friends Nagar, Cuddalore - 607001. (TN) Off: D.No: 3/2017, First Cross Street, Friends Nagar,  
Email : kgmaniv@gmail.com SEMMANDALAM, CUDDALORE - 607 001.

# Er. K.G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG. NO. M-111304/0], PPE (PANEL REG. NO M2/B0777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved Valuer / Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

DTCP Registered Structural Engineer (No. RSE / VR / May2019/007)

## FORM-E

(Form of Report to be made to the competent Authority by inspecting authorities or officers appointed under other acts under Sec. 28 of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 7 of the Madras Public Buildings (Licensing) Rules 1966 Act.

1. Name and Designation of the inspecting authority or officer appointed by or having jurisdiction under any other act or law : **Er.K.G.MANIVACHAKAM** B.E.M.I.E.F.I.V  
CHARTERED ENGINEER (INDIA),  
Class 1-A Panel Registered Engineer.
2. Location of the Building : **ARISTO PUBLIC SCHOOL**  
Door No. Street Name & : T.S.No.43/2, APS Avenue, Ward 5, Block 2  
Name of the Place : Thirupathiripuliyur  
Cuddalore City Municipal Corporation.
3. Date of Inspection : 07.02.2025
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : No defects found
6. Suggestion for rectifying defects : Does not arise
7. If in a dangerous condition immediate steps recommended to be taken : Does not arise
8. Documents referred for preparing this certificate : Building plan & Layout Sketch

Date: 11.02.2025

Signature of the Inspecting Authority/  
Officer appointed /having Jurisdiction.

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.**  
CLASS - IA REGISTERED ENGINEER  
(Under Tamil Nadu Public Building Lic. Act.)  
COLLECTERATE PANEL ENGINEER,  
Chartered Engineer, Approved Valuer  
3/201, First Cross Street, Friends Nagar,  
Cuddalore - 607 002.

For **ARISTO PUBLIC SCHOOL**

**D. C. Swal**  
Chairman.

**MATHURA PRASAD PANDEY**  
PRINCIPAL  
**ARISTO PUBLIC SCHOOL**  
APS Avenue, Gadilam Bypass Road,  
Thirupadipuliyur, Cuddalore-607002.  
Tamil Nadu, India.

3/201, 1st Cross Street, Friends Nagar, Cuddalore

Email

2-290207 Mobile: 91-98423-32323