

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE

LICENSE NO. 12 / IV /2025

Cuddalore Fire and Rescue
Service Station.

DATE : 04.03.2025

Sub : Fire and rescue service department – Cuddalore Fire and Rescue Service Station for purpose of No objection certificate – Reg.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date: 14.09.2004.
(2) G.O. No.123 School Edu (2) Dept, Date: 14.09.2004.
(3) Date of Requisition letter from The Correspondent, Aristo Public School, Cuddalore.

Based on the Govt. order mentioned above and the requisition letter given by the **Aristo Public School** at TS. No.841,843,844,845/1,845/2,Vandipalayam Road, Cuddalore, The building premises comprises of G+2(Total Plot area 10 Acres 96 Cents, Built up Area Ground Floor -1335 Sq.m, First Floor -1335 Sq.m, Second Floor-1335 Sq.m, Height of Building -11.89 m, Side Setback area all around above -6m) owned/occupied by Aristo Public School have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 04.03.2025. The school is granted No objection certificate for a period of three year (from 12.02.2025 to 11.02.2028) subject to the conditions stated below.

The above premises inspected by Assistant District Officer Fire & Rescue Services, G.Arumugam on 04/03/2025

CONDITIONS

1. This License is valid for Three year from the date of issue.
2. **Four numbers of ABC 5 Kg Extinguisher per 200 Sq.m should be provided.**
3. Fire Safety Systems should be maintained in good working condition.
4. Mock drill to be conducted periodically with the help of local fire and Rescue Service Station.
5. Any erection of permanent or temporary structure should be intimated to this department.
6. A trained Fire Service Person, preferably retired one should be appointed.
7. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq.m as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d) Periodical maintenance and care should be taken to maintain all fire


protection equipments.


- e) Mock drill has to be conducted at regular intervals in consultation with the Station Officer, Fire and Rescue Services, Cuddalore.
- f) The classrooms should always be in the ground floor upto 3rd standards.
- g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
- h) The classroom doors/ windows shall always open outwards.
- i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
- j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

L) Miniature Circuit Breakers/Earth Leakage Circuit Breakers should be provided.

M) **All the floors should be provided Down comer with Hose Reel System. (If the Condition of not fulfilled within 6 months the license will be automatically cancelled).**

If there is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.




**Asst. District Officer,
Fire & Resque Services,
Cuddalore Station.**

To:

The Correspondent,
Aristo Public School,
T.S.No.841, Vandipalayam Road,
Thirupadipuliyur, Cuddalore.


**PRINCIPAL,
ARISTO PUBLIC SCHOOL,
Affiliated to CBSE No: 193168,
Sri Singaravelavar Garden,
No:6, Vandipalayam Main Road,
Cuddalore - 607 004.**


**I.C. Swar
CHAIRMAN
ARISTO PUBLIC SCHOOL**

Sri Singaravelavar Garden,
No:6, Vandipalayam Main Road,
CUDDALORE - 607 004.